



Product Service

CERTIFICATE

No. Z10 075872 0013 Rev. 01

Holder of Certificate: **Kollmorgen Europe GmbH**

Pempelfurtstr. 1
40880 Ratingen
GERMANY

Certification Mark:



Product: **AC Servo Systems**
Model(s): **S700 Series**

Parameters: Supply voltage AC: 3* 208 - 480 VAC
or: 110 - 230 VAC
Power output: 1.0 kVA – 50 kVA

The report and the user documentation in the current valid revision are mandatory part of this certificate. The product complies with the following safety requirements only if the specifications documented in the currently valid revision of this report are met. The certified components are listed in report KR85171C-A in the current valid revision.

Tested according to:

2006/42/EC
EN 61800-5-2:2017
EN 61508-1:2010
EN 61508-2:2010
EN 61508-3:2010
EN 61800-3:2018
EN IEC 62061:2021
EN ISO 13849-1:2023
EN 61326-3-1:2017

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: KR96622T
Valid until: 2030-09-28

Date, 2025-10-08

(Christian Dirmeier)