



Product Service

# CERTIFICATE

No. Z10 075872 0011 Rev. 00


**Holder of Certificate:** **Kollmorgen Europe GmbH**

Pempelfurtstr. 1  
40880 Ratingen  
GERMANY

**Factory(ies):**

062386

**Certification Mark:**



**Product:**

**Safety components**

**Model(s):**

**AKT2G-SDI-004-000**

**Parameters:**

Supply voltage: 24VDC (-15%/+20%)  
Power dissipation: 540mW  
Protection class: IP 20

**Tested  
according to:**

2006/42/EC  
EN 61508-1:2010 (up to SIL 3)  
EN 61508-2:2010 (up to SIL 3)  
EN 61508-3:2010 (up to SIL 3)  
EN 62061:2005/A2:2015 (up to SILCL 3)  
EN ISO 13849-1:2015 (Cat. 4, PL e)  
EN 81-20:2014  
EN 81-22:2014  
EN 81-50:2014  
EN 13243:2015

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:**

KR95517T

**Valid until:**

2024-06-06

**Date,**

2020-12-17

( Claudio Gregorio )